

Dairy Farm Guide To Solar PV (Panels)

- Installing Solar Panels ("solar") can save money, add resilience, cut carbon and hedge future power price risk
- Solar operates reliably with no effort and minimal maintenance/parts replacement for an expected life of 25-30 years
- Decisions on sizing, design and supporting operational choices significantly impacts your payback



What size, cost and payback? Illustrative examples of size, cost and payback (supplier doing all the work; farms using timers to shift electricity use to use more solar)

Herd size/ system	Size kWp	Cost \$000s	Savings life \$000s	Payback Year
200/ 3.5 lower energy use	20	\$50	\$5.3	9
400/ 3.5 typical energy use	40	\$100	\$10.7	9
300/ 2.5 high pump/ irrigation	80	\$200	\$16.9	11
600/3 higher energy use	80	\$200	\$36.8	5

Big may not be best. With bigger systems, the relative savings fall as more solar is exported for lower value delaying payback. The table below illustrates saving/day on an example 650 herd farm for its peak production day with no new changes to when power is used.

Solar Size	Generation Capacity	Daily Energy Cost @ Peak Production	With changes to when power is	
No Solar		\$106	used, a 60kW	
20M x 10M panels	40kWp	\$69	farm would reduce the peak month bill to \$11/day .	
30M x 10M panels	60kWp	\$54		
40M x 10M panels	80kWp	\$40		

The average daily saving is significantly lower. A 28c/kWh retail cost of power and 17c kWh sell rate is used.

At a glance

- What is the cost and payback? This depends on the right size for your farm. The tables provide an indication.
- **Can I be more resilient?** Yes, with specific design and when there is enough sun. See next page for more.
- What do I need to ask? How they size/ design so you mostly use your own solar power. See next page.
- Will this affect my workload? Very little. Solar is handsfree for its 25-30 years apart from periodic cleaning of panels, grass/ weed control and c. year 10-15 inverter replacement. You may change timing of some work/ plant running to use more of your power (next page).
- **Rooftop or ground mount?** Arrays can go on a roof or framed in a paddock (ground mount). Roof arrays tend to suit smaller needs and may generate less as the roof direction or pitch may not be ideal but can cost less.
- **Can I save by doing work myself?** For ground mounts this is possible and can significantly reduce your payback time (as little as 4-5 years with load shifting and good sizing). Talk with different suppliers about how much you can do with their solution.
- What are the finance options? For some banks solar qualifies for their "green" loan discounts. Most installers have a pre-approved credit option. Pay as you generate (e.g. a simple cents/kWh rate) are possible as Power Purchase Agreements (PPAs) but would likely need several farmers to work with one supplier.
- Where do I find a supplier? SEANZ is the industry trade association and manages standards. Look for a member at <u>www.seanz.org.nz</u>. Local businesses that have installed on farm or at scale include Solar One and Taranaki Solar. Many national suppliers compete for larger systems.

NERGY ARM KES SENSE

ral Eneral

Dairy Guide To Solar PV/Panels

This guide is to help you check what your suppliers should talk to you about

	in morning and evening as we		
ngs to know	What you need from your supplier	milk [A], chill/ pump [B] or heat water [C]).	:
produces lots more energy in ner than winter so it is helpful iry farming.	 A design where most of your mid summer's day generation is used by your mid summer electricity use. Export reduces your payback. You do not want a proposal that generates energy to match much of your annual demand (as generation and demand happen at different times). 	But in the middle of the day solar produces more electricity.	ola
generation is highest in the e of the day (which is not y when we milk). See <i>ple 1</i> . Changes to when you ower can improve payback.	 A design using your smart meter data showing when you use power. This is to avoid lots of solar exported in the middle of the day. See <i>example 2</i> A plan for what electricity use you can shift to the middle of the day e.g. water heating, chilling and pumping with timers, smart controllers, more storage/ secondary plate cooling and/or electrical/ phase reconfiguration. You may want your electrician to check or do this. See <i>example 3</i>. 	Example 2 This image shows the generation from 40 (brown), 60 (gold) and 80 (light yellow) kW PV arrays. The high yellow generation is	
your generated power saves ur retailer rate (e.g. c. Wh). Exporting surplus r earns less (c. 7-17c/kWh), a hat may fall in the future.	 To know that much more of the solar generated is expected to be used (saving lots) rather than exported (saving less or costing you money at lower export rates from some retailers or in the future). The electricity supply and export retailer rates used. Question if the export rate is high beyond 5 years ahead and the system is not close to payback. 	exported for only c. 7- 17c/kWh reducing payback. Most of the generation from the smaller array (brown) matches demand and is used, saving money at c. 28c/kWh	3:00
resiliency needs the right ment to use your solar r to operate in power cuts n the sun is shining).	• Confirmation if the system will operate during power cuts, what plant is supported and if it works with your generator. Solar generation varies through the day and with cloud cover, so only sometimes support all your needs. A small battery can help. Ask your electrician to check and explain this.	for better payback. Example 3	airy a
ting to get electric vehicles in the near future? Solar may e network upgrade costs.	• Can the system be extended later or can this be provided for now at a small cost? When you get EV(s), smart controllers can charge from your solar (as well as night rates).	moving more loads in to the day so we use more of the solar generation and export less power (that reduces	
ical stuff – not all equipment same	 Assurance why what they supply is high quality and will be supported. Inverters are expected to need replacement in approx. 10-15 years. Confirmation the design supports the loads across all 3 phases on you farm and/ or is balanced to support the best (long running) daytime loads. 	payback). Combined with options where you can do some of the non electrical works yourself, payback can be significantly reduced.	



This typical farm's daily energy profile shows how many farms energy use peaks in morning and evening as we milk [A], chill/ pump [B] or heat water [C]).





